



# Certificate of Compliance

<b>Certificate:</b>	80224418	<b>Master Contract:</b>	302258
<b>Project:</b>	80224418	<b>Date Issued:</b>	2024-09-11
<b>Issued to:</b>	<b>Mean Well Enterprises Co., Ltd.</b> <b>No 28 Wuquan 3rd Rd</b> <b>Wugu Dist, New Taipei City 24891</b> <b>Taiwan</b>  <b>Attention:</b> Frank Lin		

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** *Kenny Chuang*  
Kenny Chuang

## PRODUCTS

Class 5311 67 POWER SUPPLIES - Component Type (CSA 62368-1)  
Class 5311 97 POWER SUPPLIES - Component Type (UL 62368-1) - Certified to US Stds

### **True Sine Wave Inverter**

Model(s)
NTS-250P-xy, NTS-400P-xy (x can be 1 or 2, y can be 12, 24 or 48)

Model No.	DC input rating	AC output rating
NTS-250P-112	12 Vdc, 25 A	Default 110 Vac, 60 Hz, 2.27 A; 100/110/115/120 Vac, 50/60 Hz selectable Rated Power: 250 W continuous
NTS-250P-124	24 Vdc, 13 A	Default 110 Vac, 60 Hz, 2.27 A; 100/110/115/120 Vac, 50/60 Hz selectable Rated Power: 250 W continuous



**Certificate:** 80224418

**Master Contract:** 302258

**Project:** 80224418

**Date Issued:** 2024-09-11

NTS-250P-148	48 Vdc, 7 A	Default 110 Vac, 60 Hz, 2.27 A; 100/110/115/120 Vac, 50/60 Hz selectable Rated Power: 250 W continuous
NTS-250P-212	12 Vdc, 25 A	Default 230 Vac, 50 Hz, 1.08 A; 200/220/230/240 Vac, 50/60 Hz selectable Rated Power: 250 W continuous
NTS-250P-224	24 Vdc, 13 A	Default 230 Vac, 50 Hz, 1.08 A; 200/220/230/240 Vac, 50/60 Hz selectable Rated Power: 250 W continuous
NTS-250P-248	48 Vdc, 7 A	Default 230 Vac, 50 Hz, 1.08 A; 200/220/230/240 Vac, 50/60 Hz selectable Rated Power: 250 W continuous
NTS-400P-112	12 Vdc, 40 A	Default 110 Vac, 60 Hz, 3.63 A; 100/110/115/120 Vac, 50/60 Hz selectable Rated Power: 400 W continuous
NTS-400P-124	24 Vdc, 20 A	Default 110 Vac, 60 Hz, 3.63 A; 100/110/115/120 Vac, 50/60 Hz selectable Rated Power: 400 W
NTS-400P-148	48 Vdc, 10 A	Default 110 Vac, 60 Hz, 3.63 A; 100/110/115/120 Vac, 50/60 Hz selectable Rated Power: 400 W continuous
NTS-400P-212	12 Vdc, 40 A	Default 230 Vac, 50 Hz, 1.73 A; 200/220/230/240 Vac, 50/60 Hz selectable Rated Power: 400 W continuous
NTS-400P-224	24 Vdc, 20 A	Default 230 Vac, 50 Hz, 1.73 A; 200/220/230/240 Vac, 50/60 Hz selectable Rated Power: 400 W continuous
NTS-400P-248	48 Vdc, 10 A	Default 230 Vac, 50 Hz, 1.73 A; 200/220/230/240 Vac, 50/60 Hz selectable Rated Power: 400 W continuous

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 62368-1:19+Upd.1 (Third Edition) - Audio/video, information and communication technology equipment — Part 1: Safety requirements - Third Edition; Update No. 1: October 2021

UL 62368-1:2019 - Third Edition - UL Standard for Safety Audio/video, information and communication technology equipment – Part 1: Safety requirements - Including revisions through October 22, 2021



**Certificate:** 80224418


**Master Contract:** 302258

**Project:** 80224418

**Date Issued:** 2024-09-11

Notes:

Products certified under Class(es) C531167, C531197 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 80224418

**Master Contract:** 302258

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80224418	2024-09-11	UL/CSA 62368-1 3rd edition for True Sine Wave Inverter, model NTS-250P-xy, NTS-400P-xy (x can be 1 or 2, y can be 12, 24 or 48)